NATIONAL TYPE EVALUATION PROGRAM

Certificate of Conformance

for Weighing and Measuring Devices

For:
Indicating Element
Electronic, Non-Computing
Model: LP7510xE-abc and LP7510xC-abc
n_{max}: 10 000
Accuracy Class: III

Submitted By:
Locosc Ningbo Precision Technology Co., Ltd.
No. 137 Zhenyong Rd. Yongjang
Ningbo, Zhejang 315021
Tel: 0086-13806678368
Fax: 86-574-87630707
Contact: Minghai Lu
Email: luminghai@locosc.com
Web site: www.locosc.com

Standard Features and Options

- Automatic Zero Tracking (AZT)
- Initial Zero Setting Mechanism (IZSM)
- Semi-Automatic Zero (Push Button)
- Semi-Automatic Tare (Push Button)
- AC Power
- DC Power / Internal Battery
- Alphanumeric Display
- Gross / Net Display
- Liquid Crystal Display
- 4-20 mA Loop
- RS-232 Communication Port
- Wireless Communication

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.

Craig VanBuren
Chairman, NCWM, Inc.

Stephen Benjamin
Chair, NTEP Committee
Issued: February 5, 2020

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.

Locosc Ningbo Precision Technology Co., Ltd.

Indicating Element / LP7510xC-abc and LP7510xE-abc

Application: General purpose indicating element when connected to an NTEP certified and compatible weighing / load receiving element.

Identification: The self-destructive identification badge may be found on the back of the indicating element.

Sealing: A wire security seal must be used by sealing two (2) predrilled sealing screws on the back of the indicator

Test Conditions: This certificate is issued based upon the following tests and upon information provided by the manufacturer. One model LP7510xC-021 and one mode; LP7510xE-021 digital weight indicators were submitted for this evaluation. Both indicators were connected to Locosc weighing / load receiving element equipped with Zemic model L6N load cells (NTEP CC 11-012) and then tested for accuracy over a temperature range of -10 °C to 40 °C (14 °F to 104 °F). The device was tested for discrimination, power interruption, zero tests. Additionally, the device was tested with a supply voltage of 100VAC to 130VAC and 5.1VDC to 6.6VDC.

Evaluated By: E. Morabito (NY)

Type Evaluation Criteria Used: *NIST Handbook 44 Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices*, 2020 Edition. *NCWM Publication 14 Measuring Devices*, 2020 Edition.

Conclusion: The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

Information Reviewed By: D. Flocken (NCWM)

Example(s) of Device:



Model LP7510xC-021 **Model LP7510xE-021**



Method of Sealing